

Wildfire Hazard Home Rating Form

Name: _____

Area: _____

Address: _____

Date: _____

<u>SUBDIVISION DESIGN</u>	<u>Points</u>	<u>FIRE PROTECTION</u>	<u>Points</u>
Ingress/Egress		Fire Response	
Two or more primary roads	1	Less than 4 minutes	1
One road	3	Greater than 4 minutes	5
One way road in, one way road out	5	Water Supply	
Width of Primary Road		Hydrant within 500 feet	1
20 feet or more	1	Hydrant farther than 500 feet	3
Less than 20 feet	3	Water source 20 min or less, round trip	5
Accessibility		Water source 20 min or more round trip	10
Road grade 5% or less	1		
Road grade more than 5%	3	<u>UTILITES</u>	
Secondary Road Terminus		Underground	1
Loop roads, cul-de-sacs with and outside radius of 45 feet or greater	1	Aboveground	5
Cul-de-sac turnaround	3	<u>CONSTRUCTION MATERIALS</u>	
Dead-end roads 200 feet or less in length	3	Siding	
Dead-end roads greater than 200 feet in length	5	Limited combustible	1
Average Lot Size		Other	5
10 acres or larger	1	Deck	
Larger than 1 acre, but less than 10 acres	3	Limited combustible with Firewise clearance	1
1 acre or less	5	Other	5
Street/Address Signs		Sofits	
All present	1	Enclosed	1
One present	3	Open	5
None present	5	Windows	
<u>VEGETATION</u>		Low E	1
Fuel Types		Double pane	3
Light	1	Single pane	5
Medium	5	Roof	
Heavy / Slash	10	Class-A Fire Rated	1
FireWise Environment		Class-B Fire Rated	3
Thinned & Rx fire	1	Class-C Fire Rated	5
Thinned only	5	Non-rated	10
No treatment	10	Stem Walls/Structural Support	
Adjacent Landscape (Within 10 feet)		Non-combustible enclosed	1
Flame resistant plants	1	Combustible enclosed	3
Flammable plants	3	Non-combustible post & beam	5
Flammable ties and timber	5	Combustible post & beam	10
<u>TOPOGRAPHY</u>			
Slope 10 % or less	1		
Slope more than 10%, but less than 20%	4		
Slope more than 20%, but less than 30%	7		
Slope 30% or more	10		
		Rating _____	

NOTES: _____

Rater: _____

Low	Less than 39
Med	40 – 59
High	60 –74
Extreme	75+